



Citizens Electric Corporation

A Touchstone Energy[®] Cooperative 

The power of human connections[®]

Member Generator System Interconnected Renewable Generation Annual Test

Date of Inspection: _____ Time: _____

Inspected by: _____, _____, _____

Member Name: _____

Address: _____

City, State, Zip: _____

Type & Size of System: _____

Annual Test to Be Completed By Member

Take voltage measurement at disconnect with generation on. _____ V

With voltmeter on generator side of disconnect, open the disconnect.

Did the voltage go to zero within 2 seconds? YES (PASS) _____ NO (FAIL) _____